MIDTOWN SPECIFIC PLAN Wastewater Questionnaire – Long Beach Water Department

If you would like to receive this questionnaire in MS Word format, please email Frances Ho at fho@placeworks.com.

 Please confirm that all wastewater generated in the Project Site would be treated at the Joint Water Pollution Control Plant (JWPCP) or Long Beach Water Reclamation Plant (WRP) of the Los Angeles County Sanitation Districts.

Based to the Local Vicinity Map (Figure 2), wastewater generated from the Project Site will be treated at the Los Angeles County Sanitation District's Joint Water Pollution Control Plant in Carson.

2. Please confirm or correct the following statements:

The current wastewater flow (in MGD) through the JWPCP is approximately 250 MGD.

JWPCP treats approximately 280 MGD and has a total permitted capacity of 400 MGD.

Long Beach WRP treats approximately 25 MGD of wastewater per day.

Contact the Los Angeles County Sanitation Districts (Wastewater Facilities) at (562) 699-7411 extension 2301 to confirm existing wastewater flows for the JWPCP and Long Beach WRP.

 Please provide any additional comments and/or information regarding water supply for the Proposed Project.

Water demand is expected to be met for the Proposed Project, but may require improvements to the water system (e.g., change in pipe size, additional appurtenances) depending on location. Projects will be reviewed and assessed individually as they come along.

Response Prepared By:

Agency	Date	
LONG BEACH WATER DEPARTMENT	41612015	
Name	Title	
JINNY HUANG	JENIOR CIVIL ENGINEER	